


Nominal Pressure	Strength testing pressure	Seat testing pressure
16K	3.3MPa	2.42MPa



DN	d	L	D	C	No-h	t	H	DI	dI	a
15	15	110	95	70	4-15	12	130	80	Tr14	4
20	20	120	100	75	4-15	14	140	100	Tr16	4
25	25	130	125	90	4-19	14	155	125	Tr18	4
32	32	160	135	100	4-19	16	165	125	Tr18	5
40	40	180	140	105	4-19	16	185	140	Tr20	6

14	Disc	H62	
13	Asbestos Free	Expanded Graphite	
12	Graphite Packing	Expanded Graphite	
11	Gland Packing	H62	
10	Split Pin	A3	Electroplating yellow
9	Nut	Q235A	Electroplating yellow
8	Gasket Ring	Q235A	Electroplating yellow
7	Handwheel	HT200	
6	Gland nut	H62	
5	Stem	H62	
4	Cover	ZCuSn5Pb5Zn5	
3	Check Washer	H62	
2	Screw	Q235A	Electroplating yellow
1	Body	ZCuSn5Pb5Zn5	
No.	Description	Material	Remark
			JIS 7409-16K
			Note
			QTY
			Proportion
Note	Handle	NO.	Sign
Date			Date
Design	Fukewei	Review	
Calibrator	Fukewei	Approver	
Process	Date	2015.1.7	